

**BSL SCAFFOLDING USA LLC**  
3975 Atascocita Way  
Humble, TX 77396  
P: 281-979-0953 / F: 281/458-3744

W/O. No.: BSL001-04-08-54760-1  
P.O. No.: 2  
Report Date: 4/8/2009

**Identification:** 10' Ringlock System

**SINGLE TIER COMPRESSIVE LOAD TEST**  
**Base Screw Jacks Set at 12" Extension**

Maximum Applied Load (lbs)	Maximum Load (lbs) Per Leg	Leg Load (lbs) at 3:1 Safety Factor
39,440	9,860	3,285



10' Ringlock System at Pre-Load




10' Ringlock at 39,440 lbs.

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Stork SWL, is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group

Respectfully Submitted

  
Terry Wilt  
Manager, Product Evaluation