

222 Cavalcade Street, 77009-3213
P.O. Box 8768, Houston, Texas 77249-8768
Tel: (713) 692-9151 Fax: (713) 696-6205

BSL Scaffolding USA LLC
3975 Atascocita Way
HUMBLE, TX 77396
P: 281 979 0953 / F: 281/458-3744

W/O. No.: BSL001-06-21-68809-1
P.O. No.:
Report Date: 6/25/2010

Sample ID Cuplock System Single Tier

**System Frame Compression Test
Loading Application in Compliance with ANSI/SSFI SC100-5/05**

Test ID	Max Load (lbs)	Load (lbs) per Leg	Loads (lbs) per Leg at 4:1 Safety Factor	Result
1	87,815	21,954	5,488	Deflection



Setup




Leg yield at 87,815 lbs

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Unless otherwise noted all test methods and specifications are to the most current revision. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Stork SWL, is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group

Respectfully Submitted


Terry Wilt
Manager, Product Evaluation

**222 Cavalcade Street, 77009-3213
P.O. Box 8768, Houston, Texas 77249-8768
Tel: (713) 692-9151 Fax: (713) 696-6205**

BSL Scaffolding USA LLC
3975 Atascocita Way
HUMBLE, TX 77396
P: 281 979 0953 / F: 281/458-3744

W/O. No.: BSL001-06-21-68809-1
P.O. No.:
Report Date: 6/25/2010

**Horizontal Ledger – Point Load
Loading Application in Compliance with ANSI/SSFI SC100-5/05**

Test ID	Max Load (lbs)	Load (lbs) at 4:1 Safety Factor	Result
1	2,436	609	Deflection



Setup




Yield at 2,436 lbs

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Unless otherwise noted all test methods and specifications are to the most current revision. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Stork SWL, is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group

Respectfully Submitted


Terry Wilt
Manager, Product Evaluation

222 Cavalcade Street, 77009-3213
P.O. Box 8768, Houston, Texas 77249-8768
Tel: (713) 692-9151 Fax: (713) 696-6205

BSL Scaffolding USA LLC
3975 Atascocita Way
HUMBLE, TX 77396
P: 281 979 0953 / F: 281/458-3744

W/O. No.: BSL001-06-21-68809-1
P.O. No.:
Report Date: 6/25/2010

**Horizontal Ledger – Uniform Load
Loading Application in Compliance with ANSI/SSFI SC100-5/05**

Test ID	Max Load (lbs)	Load (lbs) at 4:1 Safety Factor	Result
1	6,006	1,501	Deflection



Setup




Yield at 6,006 lbs

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Unless otherwise noted all test methods and specifications are to the most current revision. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Stork SWL, is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group

Respectfully Submitted


Terry Wilt
Manager, Product Evaluation